



Product Service

CERTIFICATE

No. Z10 003772 0003 Rev. 01

Holder of Certificate: **Epec Oy**
Tiedekatu 6
60101 Seinäjoki
FINLAND

Certification Mark:



Product: **Safety systems**
Programmable Logic Controller
Model(s): **Epec Safety Control Unit Family**

Parameters: Programmable Logic Controller with CODESYS SIL2 runtime
Systemtic Capability: SC3
Supply voltage: 12/24 V
Operating temperature: -40C to +85C

Tested according to: IEC 61508-1:2010 (up to SIL 2)
IEC 61508-2:2010 (up to SIL 2)
IEC 61508-3:2010 (up to SIL 2)
EN ISO 13849-1:2015 (up to PL d, Cat. 3)
EN 62061:2005/A2:2015 (up to SILCL 2)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: ES92207C
Valid until: 2025-11-09

Date, 2021-03-31

(Christian Dirmeier)